



INSPECTION REPORT

Report Issued: Jul 25, 2024 Inspection Result: PARTIAL PASS

Permit Number: SPRPL240545 Issuance Date: May 17, 2024

Property Address: 322 RIVERVIEW WAY; **Applicant:** Bellyache Mechanical

Contractor: Bellyache Mechanical PO BOX 82 Wolcott , CO 81655 (970) 470-3341

To construct: Building B New Plumbing install

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Five area deain stacks relocated to accommodate crane location. All stacks passed test of 5psi. Approved

Corrections:

Sincerely,

Ron Norton Inspector rnorton@co.routt.co.us