



INSPECTION REPORT

Report Issued: Jul 26, 2024

Inspection Result: PASSED

Permit Number: SPREL240229

Issuance Date: Mar 21, 2024

Property Address: 3300 S LINCOLN AVE;

Applicant: Flintwood Electric

Contractor: Flintwood Electric 2658 Ponderosa Road Franktown, CO 80116 (720) 320-8425

To construct: Electrical for new hotel - including sitework, low voltage, and fire alarm

On this day we have inspected your construction for **Electrical Underground/Under slab** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Underground inspection passed for spa. All rebar bonded using direct burial rated clamps with #8 on all corners and two lights.

Corrections:

Sincerely,

Dave Pieknik
Code Compliance Officer
dpieknik@co.routt.co.us