



# INSPECTION REPORT

**Report Issued:** Jul 30, 2024

**Inspection Result:** PASSED

**Permit Number:** SPRMH240711

**Issuance Date:** Jun 13, 2024

**Property Address:** 1855 SKI TIME SQUARE DR;

**Applicant:** MOUNTAIN HIGH MECHANICAL

**Contractor:** MOUNTAIN HIGH MECHANICAL 2570 Copper Ridge Dr Unit A4 Steamboat Springs, CO 80487

**To construct:** Install ERV to ventilate new fitness room.  
ERV will be a Fantech ATMO150E

On this day we have inspected your construction for **Mechanical Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** mechanical final approved for new ERV unit and ducts, contractor will be installing finished grills out in the gym area, all work approved.

**Corrections:**

Sincerely,

Todd Carr  
Building Official  
tcarr@co.routt.co.us