



INSPECTION REPORT

Report Issued: Jul 30, 2024

Inspection Result: **PARTIAL PASS**

Permit Number: SPRRN230688

Issuance Date: Jul 07, 2023

Property Address: 2300 MT WERNER CIR;

Applicant: James Eschelbach

Contractor: Haselden Construction LLC 6950 S. Potomac Street Centennial, CO 80112
(303) 728-3885

To construct: Plumbing system renovation to the Steamboat Grand Hotel/Condominiums.
We have to removed drywall only to access cavities to install new water lines.

On this day we have inspected your construction for **Drywall Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: All ceiling drywall in corridors on level 2 approved to tape, all drywall is type x 5/8 and screwed off properly

Corrections:

Sincerely,

Todd Carr
Building Official
tcarr@co.routt.co.us