



# INSPECTION REPORT

**Report Issued:** Jul 30, 2024

**Inspection Result:** PARTIAL PASS

**Permit Number:** SPRPL240545

**Issuance Date:** May 17, 2024

**Property Address:** 322 RIVERVIEW WAY;

**Applicant:** Bellyache Mechanical

**Contractor:** Bellyache Mechanical PO BOX 82 Wolcott , CO 81655 (970) 470-3341

**To construct:** Building B New Plumbing install

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Final DVW inspection for deep sections approved to the east of the separator today, all vertical lines are stubbed up. All future DWV inspections will be done above footers that are poured now. All DWV held 5 1/2 psi for 15 minutes, properly sloped and compaction under pipe, all pipe per plans for sizes.

**Corrections:**

Sincerely,

Todd Carr  
Building Official  
tcarr@co.routt.co.us