



INSPECTION REPORT

Report Issued: Jul 30, 2024

Inspection Result: PASSED

Permit Number: SPRPL240996

Issuance Date: Jul 22, 2024

Property Address: 1901 CURVE PLZ;

Applicant: Bellyache Mechanical

Contractor: Bellyache Mechanical PO BOX 82 Wolcott , CO 81655 (970) 470-3341

To construct: Installation of kitchen equipment as shown on plans.

Furnish and install new water heater as specified with recirc pump and expansion tank (Electrical by others).

Furnish and install all check valves, tempering valves, back flow preventers, etc. as specified.

Furnish and install grease interceptor as specified. Route to existing floor sink.

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: New water lines for sinks and water heater have been installed per approved plans. Lines tested live with no leaks detected. Rough plumbing approved.

Corrections:

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us