



INSPECTION REPORT

Report Issued: Aug 06, 2024

Inspection Result: **PARTIAL PASS**

Permit Number: SPRMH240896

Issuance Date: Jul 11, 2024

Property Address: 1901 CURVE PLZ;

Applicant: Bellyache Mechanical

Contractor: Bellyache Mechanical PO BOX 82 Wolcott , CO 81655 (970) 470-3341

To construct: Rework Ductwork both supply and return ,wire and install new controller for new space, Rework O/A ducting test system .

On this day we have inspected your construction for **Mechanical Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: See correction, all other duct work has been reconnected and is operational. Partial approved.

Corrections:

- 1 Update plans or provide letter from AOR stating the change from exterior Greenheck cube-099 to what is installed inline above the oven.

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us