



INSPECTION REPORT

Report Issued: Aug 09, 2024

Inspection Result: PASSED

Permit Number: SPRRF241017

Issuance Date: Aug 06, 2024

Property Address: 1901 CURVE PLZ;

Applicant: Steamboat Roofing Company LLC

Contractor: Steamboat Roofing Company LLC PO Box 771651 Steamboat Springs, CO
80477 (740) 627-1462

To construct: R&R 30 SQ 60 Mil MuleHide EPDM, install new densdack 1/4"

On this day we have inspected your construction for **Roofing Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Mid roof inspection approved, I was able to view the vapor barrier/weather barrier product installed over the plywood deck on half of the roof, this product was installed across the entire roof deck, and up the walls 6 inches or more. Then 2-layers of ISO that were 2" thick and tapered at roof drains, with 1/4" dens deck on top, then new 60 Mil MuleHide EPDM for finished product, all mid roof inspections approved.

Corrections:

Sincerely,

Todd Carr
Building Official
tcarr@co.routt.co.us