



# INSPECTION REPORT

**Report Issued:** Aug 15, 2024

**Inspection Result:** **PARTIAL PASS**

**Permit Number:** SPRRN240874

**Issuance Date:** Jul 19, 2024

**Property Address:** 2420 SKI TRAIL LN, UNIT:510;

**Applicant:** GRAHAM CUSTOM HOMES LLC

**Contractor:** GRAHAM CUSTOM HOMES LLC P.O. BOX 776338 STEAMBOAT SPGS, CO  
80477 (970) 846-5552

**To construct:** Take two existing bathrooms and relocate a shower in one bath and swap a tub for shower in the other bath. Cutting into fire rated concrete floor and replace the fire rated floor to the original fire rating. Unit #510

On this day we have inspected your construction for **Framing Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Penetrations have wire mesh installed and fire caulk, ok to pour

**Corrections:**

Sincerely,

Jeff Yeiser  
Inspector  
jyeiser@co.routt.co.us