



INSPECTION REPORT

Report Issued: Aug 20, 2024

Inspection Result: PASSED

Permit Number: SPRRF241017

Issuance Date: Aug 06, 2024

Property Address: 1901 CURVE PLZ;

Applicant: Steamboat Roofing Company LLC

Contractor: Steamboat Roofing Company LLC PO Box 771651 Steamboat Springs, CO
80477 (740) 627-1462

To construct: R&R 30 SQ 60 Mil MuleHide EPDM, install new densdack 1/4"

On this day we have inspected your construction for **Building Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: New EPDM roof is fully finished, all fasteners for Densdeck can be observed through membrane. All parapet cap flashings are installed correctly. Final approved.

Corrections:

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us