

## **INSPECTION REPORT**

Report Issued:Sep 03, 2024Inspection Result:FAILEDPermit Number:SPRSW231375Issuance Date:Dec 15, 2023Property Address:3300 S LINCOLN AVE;Applicant:Four Points Engineering - Richie Soroka <NO STREET ADDRESS> CO Don<br/>Larsen <NO STREET ADDRESS> COTo construct:Holiday Inn Express, New construction of a 63,527 GSF 4-story, 90 unit hotel

On this day we have inspected your construction for **45 Day Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Corrections required to be completed by September 5, 2024. Send photos once completed.

As mentioned during the inspection a stabilized staging area shall be constructed of non-erosive granular material at least three inches thick.

Temporary soil stabilization is required on all portions of the site where grading and land disturbing activities are complete and on any portion of the site that is inactive for at least 14 days. Examples of temporary soil stabilization include temporary seeding, hydroseeding, tackifier application, mulching, hydromulching, compacting, surface roughening, tarping, and installing erosion control

blankets. Moreover, all disturbed soils will need to be stabilized by November 1, 2024.

## **Corrections:**

- 1 Trash must be picked up daily and disposed of correctly into trash receptacles. Trash was noted floating in the ponding dewatering water and at other locations on the southeast corner of the project.
- Vehicle tracking controls were not adequate. Proper measures must be implemented immediately to minimizing tracking.
  Aggregate tracking pads for commercial, industrial, and multifamily sites, shall be constructed

of three-inch to eight-inch angular aggregate.

P.O. Box 775088, Steamboat Springs, Colorado 80477-5088 970.879.2060 \* 970.879.8851 (fax) \* steamboatsprings.net



Sincerely,

Scott Slamal Stormwater Inspector sslamal@steamboatsprings.net

> P.O. Box 775088, Steamboat Springs, Colorado 80477-5088 970.879.2060 \* 970.879.8851 (fax) \* steamboatsprings.net