



INSPECTION REPORT

Report Issued: Sep 09, 2024

Inspection Result: **PARTIAL PASS**

Permit Number: SPRRF240715

Issuance Date: Jun 27, 2024

Property Address: 2410 SKI TRAIL LN;

Applicant: Revelation Roofing

Contractor: Revelation Roofing 2659 Jacob Cir, Unit 1 Steamboat Springs, CO 80487 (972) 922-9919

To construct: Supply and Install asphalt shingles and standing seam metal. 28,428 sq ft

On this day we have inspected your construction for **Roofing Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Visual inspection from ground performed. Lower roof areas that have metal roofing to be install has Carlisle WIP300HT underlayment installed with proper laps observed. Upper roof areas that can be seen has Grace Ice and WaterShield installed. Contractor to send photos to attach to permit. Partial approved

Corrections:

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us