



INSPECTION REPORT

Report Issued: Sep 12, 2024

Inspection Result: **FAILED**

Permit Number: SPRPL240967

Issuance Date: Jul 18, 2024

Property Address: 2305 MT WERNER CIR;

Applicant: Holly Klein

Contractor: MTech Mechanical Technologies Group 12300 Pecos Street Westminster, Co 80234 (719) 782-4000

To construct: New plumbing for The Amble.

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Partial Underslab garage drains installed between grids 01-2 and 01-9 of building per approved plans. Drains did not hold pressure for test duration. Not approved

Corrections:

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us