



# INSPECTION REPORT

**Report Issued:** Sep 16, 2024

**Inspection Result:** PARTIAL PASS

**Permit Number:** SPRPL240545

**Issuance Date:** May 17, 2024

**Property Address:** 322 RIVERVIEW WAY;

**Applicant:** Bellyache Mechanical

**Contractor:** Bellyache Mechanical PO BOX 82 Wolcott , CO 81655 (970) 470-3341

**To construct:** Building B New Plumbing install

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Partial: Underground DWV and garage drains installed to approved plans on east end of garage entry, grids B8-B12 both sides. All gauges passed at 5psi. Partial approved.

**Corrections:**

Sincerely,

Ron Norton  
Inspector  
rnorton@co.routt.co.us