



# INSPECTION REPORT

**Report Issued:** Sep 17, 2024

**Inspection Result:** PASSED

**Permit Number:** SPRRF241243

**Issuance Date:** Sep 03, 2024

**Property Address:** 1847 SKI TIME SQUARE DR;

**Applicant:** Revelation Roofing

**Contractor:** Revelation Roofing 2659 Jacob Cir, Unit 1 Steamboat Springs, CO 80487 (972) 922-9919

**To construct:** Remove existing shingles, ridge caps, flashings, etc. Install Grace Ice & Water Shield over entire roof, Install GAF Professional Starter Strip on entire perimeter of roof, install GAF Timberline High Definition Asphalt Shingles per manufacturer specifications, Install custom CMG 24 gauge Flashings.

Job 4041

On this day we have inspected your construction for **Building Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Shingle install completed. New drop edge, flashing and roof jacks installed.

**Corrections:**

Sincerely,

Ron Norton



Inspector  
rnorton@co.routt.co.us