



INSPECTION REPORT

Report Issued: Sep 19, 2024

Inspection Result: NOT READY

Permit Number: SPRMH241291

Issuance Date: Aug 28, 2024

Property Address: 2700 VILLAGE DR;

Applicant: JDW INC

Contractor: JDW INC P.O. BOX 770562 STEAMBOAT SPGS, CO 80477 (970) 879-0642

To construct: THE LODGE A303

Installation of a New 2-Head Mitsubishi Split AC System

On this day we have inspected your construction for **Mechanical Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Not ready

Corrections:

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us