



INSPECTION REPORT

Report Issued: Sep 19, 2024

Inspection Result: **FAILED**

Permit Number: SPRMH241308

Issuance Date: Sep 03, 2024

Property Address: 2700 VILLAGE DR;

Applicant: JDW INC

Contractor: JDW INC P.O. BOX 770562 STEAMBOAT SPGS, CO 80477 (970) 879-0642

To construct: The Lodge - UNIT C201

Installation of a New 4-Head Mitsubishi Split AC System

On this day we have inspected your construction for **Mechanical Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: No power to units

Corrections:

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us