



INSPECTION REPORT

Report Issued: Oct 04, 2024

Inspection Result: NOT READY

Permit Number: SPRPL240967

Issuance Date: Jul 18, 2024

Property Address: 2305 MT WERNER CIR;

Applicant: Holly Klein

Contractor: MTech Mechanical Technologies Group 12300 Pecos Street Westminster, Co 80234 (719) 782-4000

To construct: New plumbing for The Amble.

On this day we have inspected your construction for **Plumbing Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: no final done today

Corrections:

Sincerely,

Todd Carr
Building Official
tcarr@co.routt.co.us