



INSPECTION REPORT

Report Issued: Oct 09, 2024

Inspection Result: PARTIAL PASS

Permit Number: SPRPL241239

Issuance Date: Aug 21, 2024

Property Address: 1760 CENTRAL PARK DR;

Applicant: Bellyache Mechanical

Contractor: Bellyache Mechanical PO BOX 82 Wolcott , CO 81655 (970) 470-3341

To construct: New Plumbing Installation

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Underground DWV installed per approved PROVENT system in units 107, 114 and 115. These units passed test of 5psi. Approved, Ok to backfill

Corrections:

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us