



INSPECTION REPORT

Report Issued: Oct 15, 2024

Inspection Result: PASSED

Permit Number: SPRNR231281

Issuance Date: Jan 22, 2024

Property Address: 3300 S LINCOLN AVE;

Applicant: Maurer Construction LLC

Contractor: Maurer Construction LLC 2621 Connery Way Missoula, MT 59808 (406) 542-6565

To construct: New construction of a 63,527 GSF 4-story, 90 unit hotel

On this day we have inspected your construction for **Wall/Roof Sheeting** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: FRWT roof sheeting installed and nailed off properly, contractor to add some nails on minor areas that got missed, they are correcting these right now. Approved to dyr in roof

Corrections:

Sincerely,

Todd Carr
Building Official
tcarr@co.routt.co.us