



## Corrections Notice

October 15, 2024

Permit Application: SPRSG241297

Property address: 2410 SKI TRAIL LN;

Following are the comments regarding the plan review for the above referenced application. We have noted several concerns and/or non-conforming items regarding the work to be performed. These items must be addressed through revised drawings submitted online through your My Items page in order to proceed.

**Planning Review** (Reviewed By: Darby Kenyon )

3. The proposed sign face exceeds the 20' sign area standard.
4. The proposed sign pole height exceeds the structural design standard. The pole height may be up to 30% maximum of the sign height.

If I can provide any further information to you, please feel free to contact me at (970) 871-8259 or by email at [dkenyon@steamboatsprings.net](mailto:dkenyon@steamboatsprings.net).

Sincerely,

A handwritten signature in cursive script that reads "Darby Kenyon".

Darby Kenyon  
Planning Technician