



# INSPECTION REPORT

**Report Issued:** Oct 17, 2024

**Inspection Result:** PARTIAL PASS

**Permit Number:** SPRPL241239

**Issuance Date:** Aug 21, 2024

**Property Address:** 1760 CENTRAL PARK DR;

**Applicant:** Bellyache Mechanical

**Contractor:** Bellyache Mechanical PO BOX 82 Wolcott , CO 81655 (970) 470-3341

**To construct:** New Plumbing Installation

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Partial: Underground DWV and Stacks for Lobby, Admin, Office and Meeting room installed per approved plans and all passed test of 5psi. Approved

**Corrections:**

Sincerely,

Ron Norton  
Inspector  
rnorton@co.routt.co.us