



INSPECTION REPORT

Report Issued: Oct 17, 2024

Inspection Result: **PARTIAL PASS**

Permit Number: SPRMH240034

Issuance Date: Jan 10, 2024

Property Address: 2964 VILLAGE DR;

Applicant: CROSS MOUNTAIN PLMB & HEAT

Contractor: CROSS MOUNTAIN PLMB & HEAT P.O. BOX 771905 STEAMBOAT SPGS,, CO
80477 (970) 819-4276

To construct: Radiant heat system, snow melt system.
South Bldg 2964 & 2968 Village Dr

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Hydronic tubing runs from main manifold in mech room to wall locations only. Mains tested and passed at 100psi. Gas line run to 4 locations, properly supported and passed test of 15psi. Approved

Corrections:

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us