



INSPECTION REPORT

Report Issued:	Oct 17, 2024	Inspection Result:	PARTIAL PASS
		•	
Permit Number:	SPRMH240036		
Issuance Date:	Jan 10, 2024		
Property Address:	2968 VILLAGE DR;		
Applicant:	CROSS MOUNTAIN PLMB 8	(HEAT	
Contractor:	CROSS MOUNTAIN PLMB 8	HEAT P.O. BOX 771905	STEAMBOAT SPGS,, CO
	80477 (970) 819-4276		
To construct:	Radiant heat system, snow	melt system.	
	South 2968 Village Dr		

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Hydronic tubing runs from main manifold in mech room to wall locations only. Mains tested and passed at 100psi. Gas line run to 4 locations, properly supported and passed test of 15psi. Approved

Corrections:

Sincerely,

Ron Norton Inspector rnorton@co.routt.co.us