



# INSPECTION REPORT

**Report Issued:** Oct 18, 2024

**Inspection Result:** PASSED

**Permit Number:** SPRSF220630

**Issuance Date:** Sep 07, 2022

**Property Address:** 1851 RIVER QUEEN LN;

**Applicant:** Saltbox Custom Homes Inc

**Contractor:** Saltbox Custom Homes Inc 5 Murray Rd. Unit B4 Edwards, CO 81632 (970) 376-7258

**To construct:** new home

On this day we have inspected your construction for **Shower Pan** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Last shower pan installed, sealed and held water for test duration. Approved

**Corrections:**

Sincerely,

Ron Norton  
Inspector  
rnorton@co.routt.co.us