



INSPECTION REPORT

Report Issued: Oct 22, 2024

Inspection Result: PASSED

Permit Number: SPRMH240278

Issuance Date: Apr 08, 2024

Property Address: 2305 MT WERNER CIR;

Applicant: Stephen Patterson

Contractor: TOLIN MECHANICAL SYSTEMS CO. 12005 E. 45TH AVE. DENVER, CO 80239-3111 (303) 859-0261

To construct: Install 2 new split systems to service the Timber and Torch compressor room.

On this day we have inspected your construction for **Mechanical Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: 2 Mini split heads installed in compressor room and both heads are operational. Condensers installed and rack outside timber and torch and are properly secured and operationl. Approved

Corrections:

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us