



INSPECTION REPORT

Report Issued: Oct 25, 2024

Inspection Result: PASSED

Permit Number: SPRMH231629

Issuance Date: Nov 08, 2023

Property Address: 1901 CURVE PLZ;

Applicant: MOUNTAIN HIGH MECHANICAL

Contractor: Steamboat Building Company, LLC 1195 BANGTAIL WAY, PO Box 774165
STEAMBOAT SPRINGS, CO 80487 (832) 457-6095

To construct: Will supply electric water heater. Will supply bathroom exhaust fans and kitchen fans. All bath fans, kitchen exhaust fans, and dryers will be vented will install 2 furnaces paired with evaporator coil and condenser.

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Duct work for furnaces, bath fans and dryers have been installed, supported and joints are sealed. Gas lines and AC line sets are installed, supported and protected correctly. Pressure tests good for 15 minutes. Rough mechanical approved.

Corrections:

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us