



INSPECTION REPORT

Report Issued: Oct 25, 2024

Inspection Result: PASSED

Permit Number: SPRPL231627

Issuance Date: Nov 08, 2023

Property Address: 1901 CURVE PLZ;

Applicant: MOUNTAIN HIGH MECHANICAL

Contractor: Steamboat Building Company, LLC 1195 BANGTAIL WAY, PO Box 774165
STEAMBOAT SPRINGS, CO 80487 (832) 457-6095

To construct: We will be doing the rough plumbing and fixtures for the new 7 individual town-home units for building 1 of Basecamp town-homes

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Units 4-7 has DWV and water lines installed, supported and protected correctly. Pressure tests are good for 15 minutes. Rough plumbing approved.

Corrections:

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us