



# INSPECTION REPORT

**Report Issued:** Oct 25, 2024

**Inspection Result:** NOT READY

**Permit Number:** SPRMH241585

**Issuance Date:** Oct 10, 2024

**Property Address:** 2700 VILLAGE DR;

**Applicant:** JDW INC

**Contractor:** JDW INC P.O. BOX 770562 STEAMBOAT SPGS, CO 80477 (970) 879-0642

**To construct:** Installation of a 2-Head Mitsubishi Split AC System

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Canceled

**Corrections:**

Sincerely,

Ron Norton  
Inspector  
rnorton@co.routt.co.us