



INSPECTION REPORT

| Report Issued: | Nov 05, 2024 | Inspection Result: | PARTIAL PASS |
|----------------|--------------|--------------------|--------------|
| | | | |

Permit Number: SPRPL240603 Issuance Date: May 29, 2024

Property Address: 3300 S LINCOLN AVE;

Applicant: Scott Sypniewski

Contractor: Scott Sypniewski, LLC 8045 Noble Fir Court Colorado Springs, CO 80927

To construct: plumbing for hotel

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Gas line main, needed for temp heat, holding 15 psi, stop valves installed

Corrections:

Sincerely,

Jeff Yeiser Inspector jyeiser@co.routt.co.us