



INSPECTION REPORT

Report Issued: Nov 05, 2024

Inspection Result: PASSED

Permit Number: SPRMH241469

Issuance Date: Sep 24, 2024

Property Address: 2700 VILLAGE DR;

Applicant: JDW INC

Contractor: JDW INC P.O. BOX 770562 STEAMBOAT SPGS, CO 80477 (970) 879-0642

To construct: Installation of a 2-Head Mitsubishi Split AC System

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Two mini split wall mounted heads installed with condensate run to outside. Heads connected to condenser and operational. Holes for line sets and condensate properly drilled.
Approved

Corrections:

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us