



# INSPECTION REPORT

**Report Issued:** Nov 13, 2024

**Inspection Result:** PASSED

**Permit Number:** SPRMH231639

**Issuance Date:** Nov 09, 2023

**Property Address:** 1851 RIVER QUEEN LN;

**Applicant:** Isidro Quezada

**Contractor:** IQ PLUMBING & HEATING 895 RANNEY ST CRAIG, CO 81625 (970) 629-5125

**To construct:** In floor heating system for home at 1851 River Queen Lane.

On this day we have inspected your construction for **Approval for Gas Service** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Boiler properly installed and vented. Boiler hooked to gas line and ready to fire. Green tag issued.

**Corrections:**

Sincerely,

Ron Norton  
Inspector  
rnorton@co.routt.co.us