



INSPECTION REPORT

Report Issued: Nov 26, 2024

Inspection Result: PASSED

Permit Number: SPRMH240927

Issuance Date: Jul 16, 2024

Property Address: 1855 SKI TIME SQUARE DR, UNIT:804;

Applicant: HOT STUFF HEARTH & HOME

Contractor: HOT STUFF HEARTH & HOME 1625 MID VALLEY DR #3 STEAMBOAT SPGS, CO
80487 (970) 879-7614

To construct: New gas fireplace - FPX 864

On this day we have inspected your construction for **Mechanical Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Contractor never called for any rough inspections to be completed on the install of this fireplace, we were called today for a final, the final inspection was approved with a gas key valve installed in the front, the unit was operational and working when turned on.

Corrections:

Sincerely,

Todd Carr
Building Official
tcarr@co.routt.co.us