



# INSPECTION REPORT

**Report Issued:** Dec 12, 2024

**Inspection Result:** PASSED

**Permit Number:** SPRMH240034

**Issuance Date:** Jan 10, 2024

**Property Address:** 2964 VILLAGE DR;

**Applicant:** CROSS MOUNTAIN PLMB & HEAT

**Contractor:** CROSS MOUNTAIN PLMB & HEAT P.O. BOX 771905 STEAMBOAT SPGS,, CO  
80477 (970) 819-4276

**To construct:** Radiant heat system, snow melt system.  
South Bldg 2964 & 2968 Village Dr

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Hydronic tubing installed and properly fastened to subfloor. All zones connected to main manifold in mechanical room and passed test of 100psi. Approved, Ok to pour Gypcrete.

**Corrections:**

Sincerely,

Ron Norton  
Inspector  
rnorton@co.routt.co.us