



# INSPECTION REPORT

**Report Issued:** Dec 20, 2024

**Inspection Result:** PASSED

**Permit Number:** SPRPL241439

**Issuance Date:** Sep 18, 2024

**Property Address:** 1206 LINCOLN AVE;

**Applicant:** ROUTT PLUMBING & HEATING LLC

**Contractor:** ROUTT PLUMBING & HEATING LLC 3725 LINCOLN AVE UNIT 35 STEAMBOAT  
SPGS, CO 80487-4959 (970) 819-8157

**To construct:** Replace DWV and Domestic Water

On this day we have inspected your construction for **Plumbing Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Fixtures installed, sealed and operational. Approved

**Corrections:**

Sincerely,

Ron Norton  
Inspector  
rnorton@co.routt.co.us