



INSPECTION REPORT

Report Issued: Dec 20, 2024

Inspection Result: PASSED

Permit Number: SPREL241171

Issuance Date: Aug 13, 2024

Property Address: 1206 LINCOLN AVE;

Applicant: NORTHWEST ELECTRICAL SYSTEMS

Contractor: NORTHWEST ELECTRICAL SYSTEMS P.O. BOX 393 YAMPA, CO 80483

To construct: remodel electrical

On this day we have inspected your construction for **Electrical Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Final electrical approved

Corrections:

Sincerely,

Tom Cook
Electrical Plan Reviewer/Inspector
tcook@co.routt.co.us