



Corrections Notice

January 07, 2025

Permit Application: SPRROW250001

Property address: 322 RIVERVIEW WAY;

Following are the comments regarding the plan review for the above referenced application. We have noted several concerns and/or non-conforming items regarding the work to be performed. These items must be addressed through revised drawings submitted online through your My Items page in order to proceed.

ROW Permit Review - Engineering (Reviewed By: Adan Camano)

- Add a note that clarifies the time and day the crane will be active for. You indicated 7am-4pm 1/8-1/10. Please add that to the plan.
- Add the road closure signs to the plan.
- Add a note that flaggers will be posted for the full or partial duration of the work for the crane. Add the location where the flaggers will be posted.
- Show the pedestrian rerouting path at the south sidewalk.

If I can provide any further information to you, please feel free to contact me at (970) 871-7019 or by email at acamano@steamboatsprings.net.

Sincerely,
Adan Camano
Staff Engineer