



INSPECTION REPORT

Report Issued: Jan 08, 2025

Inspection Result: **PARTIAL PASS**

Permit Number: SPRMH231629

Issuance Date: Nov 08, 2023

Property Address: 1901 CURVE PLZ;

Applicant: MOUNTAIN HIGH MECHANICAL

Contractor: Steamboat Building Company, LLC 1195 BANGTAIL WAY, PO Box 774165
STEAMBOAT SPRINGS, CO 80487 (832) 457-6095

To construct: Will supply electric water heater. Will supply bathroom exhaust fans and kitchen fans. All bath fans, kitchen exhaust fans, and dryers will be vented will install 2 furnaces paired with evaporator coil and condenser.

On this day we have inspected your construction for **Approval for Gas Service** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Units 1-4 have furnaces installed and vented correctly and are ready to operate. Green tags issued.

Corrections:

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us