



INSPECTION REPORT

Report Issued: Jan 13, 2025

Inspection Result: NOT READY

Permit Number: SPREL231812

Issuance Date: Dec 21, 2023

Property Address: 1901 CURVE PLZ;

Applicant: JCH ELECTRIC LLC

Contractor: JCH ELECTRIC LLC P.O. BOX 881262 STEAMBOAT SPGS, CO 80488 (970) 819-1895

To construct: New electrical wiring

On this day we have inspected your construction for **Electrical Perm Service** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: service currently has 7 meters and requires an 8th meter for house panel. plans and load calc do not reflect house panel and heat tape/site lighting loads. alteration of service will require resubmittal for review prior to energizing service.

Corrections:

Sincerely,

Tom Cook
Electrical Plan Reviewer/Inspector
tcook@co.routt.co.us