



INSPECTION REPORT

Report Issued: Jan 16, 2025

Inspection Result: **PARTIAL PASS**

Permit Number: SPRPL240545

Issuance Date: May 17, 2024

Property Address: 322 RIVERVIEW WAY;

Applicant: Bellyache Mechanical

Contractor: Bellyache Mechanical PO BOX 82 Wolcott , CO 81655 (970) 470-3341

To construct: Building B New Plumbing install

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Units 203, 204, 205, 207, 209, 303, 304, 305, 307, 309, 404, 405, 407, 409 have DWV lines installed, protected and supported correctly. Pressure tests good at 5 psi for 15 minutes. Partial approved.

Corrections:

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us