



INSPECTION REPORT

Report Issued: Feb 05, 2025

Inspection Result: **PARTIAL PASS**

Permit Number: SPRPL240545

Issuance Date: May 17, 2024

Property Address: 322 RIVERVIEW WAY;

Applicant: Bellyache Mechanical

Contractor: Bellyache Mechanical PO BOX 82 Wolcott , CO 81655 (970) 470-3341

To construct: Building B New Plumbing install

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Water lines for all units on floors 2, 3, 4 are installed correctly. Pressure tests good for 15 minutes. Fire caulking, insulation and nail plates still to be installed.

Corrections:

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us