



# INSPECTION REPORT

**Report Issued:** Feb 05, 2025

**Inspection Result:** **PARTIAL PASS**

**Permit Number:** SPRAD240306

**Issuance Date:** Sep 19, 2024

**Property Address:** 2700 VILLAGE DR;

**Applicant:** GARCIA CONSTRUCTION LIMITED

**Contractor:** GARCIA CONSTRUCTION LIMITED 1153 OAK STREET STEAMBOAT SPRINGS,  
CO 80477 (970) 757-3250

**To construct:** addition of a 8004SF storage facility over an existing 8004SF concrete parking structure.

On this day we have inspected your construction for **Insulation Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Partial: Floor system has R38 batts installed on east half of building. Approved to install sheeting

**Corrections:**

Sincerely,

Ron Norton  
Inspector  
rnorton@co.routt.co.us