



INSPECTION REPORT

Report Issued: Feb 06, 2025

Inspection Result: **PARTIAL PASS**

Permit Number: SPRMH250017

Issuance Date: Jan 10, 2025

Property Address: 322 RIVERVIEW WAY;

Applicant: Air Comfort, Inc.

Contractor: Deneuve Design, Inc dba Deneuve Consrt. Serv 2344 Spruce Strt Ste B
Boulder, Co 80302

To construct: Mechanical HVAC

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: 4th floor unit line sets are installed, supported and protected correctly. Pressure tests good above 300 PSI for 15 minutes.

Corrections:

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us