



INSPECTION REPORT

Report Issued: Feb 21, 2025

Inspection Result: **PARTIAL PASS**

Permit Number: SPRPL250145

Issuance Date: Feb 20, 2025

Property Address: 1920 BRIDGE LN;

Applicant: J & I Plumbing and Heating Services LLC

Contractor: J & I Plumbing and Heating Services LLC 1664 Yampa Ave Craig, CO 81325

To construct: Add a washer box for a washer dryer.

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: New DWV and water lines for washer box are installed correctly. Tested live with no leaks detected. Need nail plates on water lines in three studs. Partial approved.

Corrections:

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us