



INSPECTION REPORT

Report Issued: Feb 24, 2025 Inspection Result: PARTIAL PASS

Permit Number: SPRPL240546
Issuance Date: May 17, 2024

Property Address: 355 RIVERVIEW WAY;

Applicant: Bellyache Mechanical

Contractor: Bellyache Mechanical PO BOX 82 Wolcott , CO 81655 (970) 470-3341

To construct: Building E New Plumbing Install

STOP WORK ORDER generated on 07/31/2024 by username 'Nick Neiberger'. STOP WORK ORDER removed on 01/13/2025 by username 'Nick Neiberger'.

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Partial: DWV installed per approved plans for units 311,314,411 and 414. Pipes properly supported and passed test 5psi. Approved

Corrections:

Sincerely,

Ron Norton Inspector rnorton@co.routt.co.us