



INSPECTION REPORT

Report Issued: Mar 03, 2025

Inspection Result: PASSED

Permit Number: SPRMH241645

Issuance Date: Oct 18, 2024

Property Address: 2964 VILLAGE DR;

Applicant: Mountain Home Stove & Fireplace

Contractor: Mountain Home Stove & Fireplace P.O. BOX 775491 Steamboat Springs, CO
80477 (970) 879-7962

To construct: Installing 2 gas fireplaces in south building duplex

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Powerer venter /exhaust now lower to meet manufactures requirements.
Approved

Corrections:

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us