



INSPECTION REPORT

Report Issued: Mar 06, 2025

Inspection Result: **PARTIAL PASS**

Permit Number: SPRPL240132

Issuance Date: Feb 10, 2024

Property Address: 2940 VILLAGE DR; 2944 VILLAGE DR; 2948 VILLAGE DR; 2956 VILLAGE DR; 2936 VILLAGE DR;

Applicant: CROSS MOUNTAIN PLMB & HEAT

Contractor: CROSS MOUNTAIN PLMB & HEAT P.O. BOX 771905 STEAMBOAT SPGS,, CO 80477 (970) 819-4276

To construct: New construction DWV, water piping, gas piping, and fixture set.

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Units two through five have DWV, waterlines, gas lines installed, protected, and supported correctly. Pressure test good for 15 minutes. Partial approved.

Corrections:

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us