



# INSPECTION REPORT

**Report Issued:** Mar 06, 2025

**Inspection Result:** **PARTIAL PASS**

**Permit Number:** SPRMH250212

**Issuance Date:** Mar 05, 2025

**Property Address:** 2940 VILLAGE DR; 2944 VILLAGE DR; 2948 VILLAGE DR; 2956 VILLAGE DR; 2936 VILLAGE DR;

**Applicant:** Steamboat Heat LLC

**Contractor:** Steamboat Heat LLC 32555 County Road 38 Steamboat Springs , CO 80487  
(970) 581-6978

**To construct:** HVAC and all mechanical ventilation.  
2936, 2940, 2944, 2948, 2956 Village DR

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Units 2-5 Ductwork for bath fans, air handling, and dryer vents have been installed, supported, sealed correctly. AC line sets have been installed and protected correctly. Will need to do pressure test at later date and install a few nail plates. Partial approved.

**Corrections:**

Sincerely,

Silas Ebbert  
Inspector  
sebbert@co.routt.co.us