



INSPECTION REPORT

Report Issued: Mar 19, 2025

Inspection Result: PASSED

Permit Number: SPRMH241914

Issuance Date: Dec 24, 2024

Property Address: 1920 BRIDGE LN, UNIT:14;

Applicant: Karl Holt

Contractor:

To construct: A range hood vent and bathroom exhaust fan were added without permits.

On this day we have inspected your construction for **Mechanical Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: All existing mechanical work is complete and approved. All penetrations through fire rated assemblies are ok. Final approved.

Corrections:

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us