



INSPECTION REPORT

Report Issued: Mar 19, 2025 Inspection Result: PARTIAL PASS

Permit Number: SPRMH240034
Issuance Date: Jan 10, 2024
Property Address: 2964 VILLAGE DR;

Applicant: CROSS MOUNTAIN PLMB & HEAT

Contractor: CROSS MOUNTAIN PLMB & HEAT P.O. BOX 771905 STEAMBOAT SPGS,, CO

80477 (970) 819-4276

To construct: Radiant heat system, snow melt system.

South Bldg 2964 & 2968 Village Dr

On this day we have inspected your construction for **Approval for Gas Service** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Underground gas line installed in trench of proper depth with trace wire from meter location around to firepit location. Gas line passed pressure test of 16psi. Approved

Corrections:

Sincerely,

Ron Norton Inspector rnorton@co.routt.co.us